

BINDESHWAR PANDIT

B.E(Civil), FIV, MIE

MCD Licensed Engineer E-1753
MCD Structural Engineer S.E-26
Govt. Regd. Valuer U/S 34 (AB) of 1957
Regd.No.-CAT-1/628/176/2014-15
Structural Designer
Chartered Engineer
Registered Valuer IBB
Ref.No.91/SSC/DEL/SPS RN/2021

Address:
264, D.A Flat, Phase-IV
Nimri Colony, Ashok Vihar
Delhi-110052
Mobile No.-9810988628, 9821368002
E-mail ID :-bpandit2013@gmail.com

Date: 11.01.2021

STRUCTURE STABILITY CERTIFICATE

Address of Property : Salwan Public School, Old Rajinder Nagar,
New Delhi- 110060

Name of Owner : Salwan Public School
C/o Salwan Education Trust

School Building comprising of Block Nos 'A', 'B', 'D', 'E', and 'F', is bounded as under:-
North -Public Road South -Road
East - Salwan Girls School and Road West -Road

I have visually inspected the above cited School Buildings on dated 08.01.2021 at 3:00 PM. The details of these buildings are mentioned below:-

Ser No	Name of Block	No of Floors	Total Covered Area (Sqm)	Year of Construction	Remarks
(a)	'A' Block	Ground + 1	1514.45	1950	RCC, Framed
(b)	'B' Block	Ground + 2	1422.73	1950	Load Bearing walls
(c)	'D' Block	Ground + 2	915.76	1953	
(d)	'E' Block	Ground + 1	457.83	1990	
(f)	'F' Block	Ground + 1	1462.15	1990	RCC, Framed
(g)	Multi Purpose Hall	Ground + 1	518.13	2000	

All of the above mentioned existing building are less than 15 m in height and satisfy the structural safety requirements including safety from natural hazards based on soil conditions.

In my view the above said buildings are safe and sound.



B. Pandit
(Bindeshwar Pandit)
Structure Engineer

BINDESHWAR PANDIT
MCD Structural Engineer
License No. SE-26
264, D.A. Flats, Nimri Colony
Ph-IV, Ashok Vihar, Delhi-52